

ADDENDUM

Addendum No. 001

Quotation: Ammonia Ice Plant Repairs

Item No: #L-41 City File #78/23

Date: May 11, 2023

A. GENERAL

1. This Addendum is issued prior to Quotation closing to provide for certain revisions as noted herein.
2. All such revisions will become part of the Work and the effects shall be included in the Total Bid Price.
3. All Work shall be performed in accordance with the Quotation Documents.
4. Bidders shall acknowledge receipt of this Addendum in the space provided on the Bid Form.
5. The closing date for this Quotation **is still** Tuesday, May 16, 2023 at 5:00:00 p.m. local Brandon time.
6. **In the event you have already submitted a Bid and this Addendum caused you to change it, a revised Bid will need to be submitted. If there are no changes to the Bid Submission, written confirmation of receipt of this Addendum is required. Written confirmation shall be sent to purchasing@brandon.ca.**

B. SPECIFICATIONS

1. Refer to Appendix 1 Specifications, Item #B.2 Shell and Tube Chiller – Revise to read as:

Make	Unknown
Model	Unknown
Serial Number	5454133

2. Refer to Appendix 1 Specifications, B.4 Compressor 2, Item #B.4.1.1 – Revise to read as:

Replace the existing compressor with 80hp motor **or** with compressor and motor rated for a 110 ton ammonia ice plant with 2 compressors.

END OF DOCUMENT